

COUNTY OF KENOSHA
REQUEST FOR BID (RFB) #2202
COUNTYWIDE FIRE INSPECTION –
2202D – KITCHEN HOODS

KITCHEN FIRE SUPPRESSION SYSTEM INSPECTION

Bidders shall provide services for the kitchen fire suppression hoods located at various county facilities. The inspections and services shall comply with all the latest NFPA codes and NFPA 17A and the manufactures manual.

- **Maintenance and Testing:**
 - Provide semi-annual maintenance in accordance with the latest NFPA code and the manufacturer's listed maintenance manual.
 - Container Test: The following parts of the wet chemical extinguishing systems shall be subjected to a hydrostatic pressure test at intervals not exceeding 12 years.